



Jeremiah W. (Jay) Nixon, Governor • Sara Parker Pauley, Director

DEPARTMENT OF NATURAL RESOURCES

www.dnr.mo.gov

CI

North Central Missouri Regional Water Commission
Review No. 2050413-13
PWS ID #MO2021537

October 25, 2013

Mr. Bobby Williams, President
201 North Market Street
Milan, MO 63556

Dear Mr. Williams:

An Engineering Report for water system improvements for North Central Missouri Regional Water Commission, Milan, Missouri has been reviewed. The report was examined as to sanitary features which may affect the operation of the system, including size, capacities, of units, and factors which may affect efficiency and ease of operation. Approval of the engineering report as regards to these points is hereby given. This approval is valid for two years.

It is suggested that you proceed to make arrangements for financing the proposed projects and instruct your engineer to prepare the necessary detailed plans and specifications for the proposed improvements. Hydraulic analysis demonstrating adequate flow and pressure must be submitted with the detailed plans and specifications.

Regulations require written approval of detailed plans and specifications before awarding the contract or initiating construction. Upon receipt of the detailed plans and specifications, we will proceed with our review and advise you by written report of our approval. An updated engineering report must be submitted with the detailed plans and specifications if there is a change in the scope of the project or if the original report is more than 2 years old. Should you have any questions please contact Kimberly Potter at 573/751-5924.

Sincerely,

WATER PROTECTION PROGRAM

A handwritten signature in cursive script, reading "Maher Jaafari".

Maher Jaafari Ph. D., P. E., Chief
Infrastructure Permits and Engineering Section
Public Drinking Water Branch

MJ:rsd

c: Mr. Chad W. Sayre, Allstate Consultants LLC
Northeast Regional Office

